

DAVID BRANTLEY & SONS

-TANK IS DESIGNED AND CONSTRUCTED TO H20 TRAFFIC BEARING LOAD RATING WITH A MINIMUM STRENGTH OF 5,000 psi.

-TANK IS SINGLE PIECE CONSTRUCTION WITH LID BEING SECURED WITH 1.5x1.5 INCH BUYTL RUBBER MASTIC SEALANT.

-KNOCKOUTS WILL HAVE CAST IN PLACE PRESS SEAL BOOTS TO RECEIVE 4 INCH PIPE.

-BOTH ACCESS COVERS WILL HAVE MANHOLE RINGS WITH STANDARD MANHOLE COVERS

- CAPACITY 1,500 GALLONS

37 Pine Ridge Rd. Zebulon, NC 27597 Office 252-478-3721 Fax 919-573-0443

1installer•gmail.com

| PREPARED FOR : | David Brantley & Sons 37 Pine Ridge Rd. Zebulon, NC 27597 | REVISION NO. | DATE | BRANTLEY TANK MODEL |
|----------------------|---|--------------------|----------------|----------------------------|
| | | Original Submittal | April 11, 2014 | |
| DATE A WAY | | Revision 1 | | 1,500 H20 GT Greenville |
| DATE: April 11, 2014 | | Revision 2 | | Greenville |
| CONTACT: | | | | |
| CORY BRANTLEY | | Revision 3 | | SHEET NUMBER |
| | | Master Set | |] 1 of 1 |
| | | | | 1 ' • ' ' |